

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
1	Galiveedu PS-1	-	NPKunta PS	APSPCL	Yes	No	Not working	Status update on VOIP and firewall. VOIP of Athena P1, P3, Adani, Azure-I, Indigrid 1 &2, Tata not working. No response during agenda point
	Tata Power Galiveedu PS-1	100	NPKunta PS	APSPCL	Yes	No	Not working	
	ACME-1 (Galiveedu PS1)	50	NPKunta PS	APSPCL	Yes	No	Not working	
	ACME-3 (Galiveedu PS1)	50	NPKunta PS	APSPCL	Yes	No	Not working	
	FRV-1 (Galiveedu PS1)	50	NPKunta PS	APSPCL	Yes	No	Not working	
	Galiveedu PS-2	-	NPKunta PS	APSPCL	Yes	No	Not working	
	ACME –6 (Galiveedu PS-2)	50	NPKunta PS	APSPCL	Yes	No	Not working	
	Galiveedu PS-3	-	NPKunta PS	APSPCL	Yes	No	Not working	
	AZURE (Galiveedu PS-3)	50	NPKunta PS	APSPCL	Yes	No	Not working	
	FRV-2 (Galiveedu PS-3)	50	NPKunta PS	APSPCL	Yes	No	Not working	
2	NTPC Limited	250	NPKunta PS	NTPC Green	NA	Yes	Not working	
	SB Energy Solar Pvt Ltd	250	NPKunta PS	Adani	NA	Yes	Not working	
	NPK PS-1	-	NPKunta PS	APSPCL	Yes	No	Not working	

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
	NPK PS-4	-	NPKunta PS	APSPCL	Yes	No	Not working	
3	NPK PS-2	-	NPKunta PS	APSPCL	Yes	No	Not working	No response during agenda point
4	NPK PS-3	-	NPKunta PS	APSPCL	Yes	No	Not working	
5	Renew Wind Energy (TN2) Pvt Ltd	50	Pavagada PS	Renew		No	Not working	No response during meeting
	Yarrow Infrastructure Pvt Ltd	50	Pavagada PS	Vector Green	NA	No	Not working	Earlier KSPDCL stated that they will take it up with OEM (GE) and get back by 1st week of April 2025, During the discussion, CTUIL highlighted the 2+2 channels requirement for old plants as well and requested to submit the action plan in this regard. However same is pending till date. Special meeting needs to be done for Pavagada of KSPDCL for FOTE and integration with ULDC network
	ACME Kurukshetra Solar Energy Pvt Ltd	50	Pavagada PS	Amplus Energy	NA	No	Not working	
	ACME Rewari Solar Energy Private Limited	50	Pavagada PS	Amplus Energy	NA	No	Not working	
	Azure power earth Private Limited	100	Pavagada PS	Azure	NA	No	Not working	
	Fortum Fin Surya Energy Private Limited	100	Pavagada PS	fourth partner	NA	No	Not working	
								No response during last meeting

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
	Paramapujya Solar Energy Private Limited	150	Pavagada PS	Adani	NA	Yes	Not working	No response during meeting
	Avaada Solar Energy Private Limited	150	Pavagada PS	Avaada	NA	No	Not working	
	Fortum solar India Private Limited	250	Pavagada PS	Spring Energy	NA	Yes	Not working	
	KREDL (GoK)	50	Pavagada PS	KREDL	NA	No	Not working	
	Tata Power Renewable Energy Limited	400	Pavagada PS	Tata	NA	No	Not working	
	SBGPAVAGADA	200	Pavagada PS	Adani	NA	Yes	Not working	Firewall installation is in process
	Avaada Solarise Energy Pvt Ltd	150	Pavagada PS	Avaada	NA	No	Not working	No response during meeting
	Adyah Solar Energy Private Limited	300	Pavagada PS	Ayana	NA	No	Not working	No response during meeting
6	RGDM_FSP	100	Ramagundam PS	NTPC Green	Yes	Yes	Not working	Dual channels yet to provide, site informed configuration issues .NTPC revised schedules from April 2025 to Nov 2025 and no commitment in last RE Sub Committee Meeting.
7	Simhadri FS	25	Simhadri PS	NTPC Green	Yes	Yes	Not working	No response on VOIP issues

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
8	Kayamkulam solar	92	Kayamkulam PS	NTPC Green	No	No	Not Working	Details shared with site in Dec 2025. Installation of firewall awaited from OEM and expected within 1 week. VOIP-Configuration pending and procurement of the hardware planned within 2-3 days. No response
9	Greenko Sironj	200	Tuticorin PS	Greenko	No	Yes	Working	Firewall:One firewall is already configured and the channels reporting to backup SRLDC is yet to be configured through firewall. Expected to completed with end of March 2026.
10	Greenko/Amgepl	2620	Kurnool	Greenko	No	Yes	Not Working for Greenko Solar	As per the undertaking from Greenko, UNMS integration will be completed by 31 <sup>st</sup> Jul 2026.
11	Betamwind	220	Tuticorin PS	Betam (ENGIE)	Yes	No	Working	Timeline for firewall configuration revised from Nov 2025 . Yet to be configured. No response during 4 <sup>th</sup> RE meeting and to mails.

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
12	Girel (Chandragiri)	250	Tuticorin PS	SEMBCORP	No	Yes	Not working	VOIP status
13	Dharapuram	300	Karur	JSW	No	Yes	Not Working	VOIP Status
14	JSWF1	300	Tuticorin PS	JSW	No	Yes	Working	UNMS- FOTE vendor will visit for integration within 1 <sup>st</sup> week of March

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
15	JSWF2	150	Tuticorin PS	JSW	No	Yes	Working	2026 and expected to resolve the issue by 31 <sup>st</sup> March 2026. Integration is still pending.
16	JSWF3	150	Tuticorin PS	JSW	No	Yes	Not Working	
17	Spring Agnitra Pvt Ltd	250	NPKunta PS	Spring Energy	#N/A	No	Not working	M/s Spring Solar has informed that they VLAN work will be completed by 31 <sup>st</sup> Oct 2025 and VOIP by 15 <sup>th</sup> Nov 2025. No response during 4 <sup>th</sup> RE sub committee meeting
18	Ayana Wind	300	Koppal PS	Ayana	No	Yes	Working	Dual channels to Backup CC provided on 25 <sup>th</sup> May 2026. Integration with UNMS pending
19	Ayana AnanthapuramSolar Pvt Ltd	250	NPKunta PS	Ayana	#N/A	No	Not working	As per last meeting, Ayana informed that they will coordinate with APSPCL (NPK PSS2) and revert back to SRLDC by 1st Week of April 2025, along with firewall integration. In Nov 2025, SDH will be commissioned and VLAN and dual channels to BCC will be provided No response during meeting

Annexure-5								
Sl.No	Developer/ RE Generator	Installed Capacity [MW]	Connected to 400/220KV ISTS Pooling Station	Responsible Entity	FOTE/entity NMS Integration with SR- UNMS	Whether Configured Firewall towards SRLDC (yes/No)	VOIP Connectivity to SRLDC	Last RE Subcommittee Meeting Deliberations
20	SRIPL 1(SERANTICA)	195	Koppal PS	Serentica	No	Yes	Working	Issue of FOTE at Koppal end resolved. Action plan of Serentica yet to receive. No response from Serentica during meeting. Vide mail dated 29 <sup>th</sup> May 2026 SRIPL informed that order placed for procurement of additional Eth card. The work will be completed before 30 <sup>th</sup> June 2026.