

Detailed Report

Date of Submission : 01-06-2026 21:36

EXORA - 220KV tripped at 29-05-2026 17:35 and restored at 01-06-2026 21:34

Summary of Event (घटना का सारांश) :

Time and Date of the event (घटना का समय और दिनांक) : 29-05-2026 17:35

Name of the Substation/Generating Station/Pooling Station affected (Along with Voltage level) : EXORA - 220KV

Event Category (श्रेणी के साथ इवेंट प्रकार) : GD - 1

Location/Control Area (स्थान/नियंत्रण क्षेत्र) : KARNATAKA

Configuration of Bus (HV/LV) . Along with details of Bus split Operation (if any) :

Bus Configuration Type : Double Bus with Bus coupler

Bus Coupler Status : NA

Bus 1 Connected Elements	Bus 2 Connected Elements	Bus 3 Connected Elements	Bus 4 Connected Elements
1. 220KV-MALUR-EXORA-1			

Station Connectivity / SLD during antecedent :

Weather Conditions : Cloudy

**Elements under outage
prior to the event** :

**Other Information
(Antecedent Cnditions)** : Main supply failure from 220kv malur R/S as
220kv HOODY Malur line tripped at malur
end, zone-1, R-ph, loc- 16.68kms, IA- 940.1A

Renewable Energy Trip : False

**Details of SPS Operation
(if any):** : False

Reason of tripping : Others

Other Reason : MSF

**Load and Generation Loss
(लोड और जेनरेशन हानि)** :

Total Generation Loss (MW)	Total Load Loss(MW)
75 MW	75 MW

**Duration of interruption
(रुकावट की अवधि)** :

**Details of Equipment
Failure (if any during the
event):** :

Equipment Type	Equipment Make
----------------	----------------

**List of elements tripped
during the event** : 1. EXORA - 220KV

**Station Connectivity/SLD
during the event** :

Analysis of the event : 220kv HOODY Malur line tripped at malur
end, zone-1, R-ph, loc- 16.68kms, IA- 940.1A

**Protection / Operational
Issues observed** :

Restoration Details :

DR Time synchronization	:	False
issues observed (सुरक्षा/प्रचालन समस्या)	:	
Remedial Measures Taken (सुधारात्मक सुझाव)	:	Test charged and stood ok
Relay/PLCC Operation Details	:	
Control Panel Anunciation	:	Nil
Main I Relay Indications	:	Nil
Main II Relay Indications	:	Nil
Other Relay Indications	:	
PLCC Counter Increment I/T	:	nill
PLCC Counter Increment D/T	:	nill
Fault Current Value (kAmp)	:	0.0
LA Counter	:	NA
Remarks	:	
Attachments	:	