



भारत सरकार
केन्द्रीय विद्युत प्राधिकरण
दक्षिण क्षेत्रीय विद्युत समिति
29, रेस कोर्स क्रॉस रोड
बेंगलुरु -560 009



Government of India
Central Electricity Authority
Southern Regional Power Committee
29, Race Course Cross Road
BENGALURU - 560 009



Phone : 080 -22209612 ;
No. SRPC/SE-(C)/FRP/2026/

e-mail: secommmlsrpc-ka@nic.in ;

web site: www.srpc.gov.in

दिनांक/ Dated: 20th August 2026

सेवा में / To

Head (ERCG)
UPCL (Adani Power Ltd.)
Bengaluru

विषय : जुलाई 2026 माह के लिए एपीएल उडुपी के औसत मासिक आवृत्ति प्रतिक्रिया प्रदर्शन (β) का प्रमाण पत्र।

Sub: Certificate of Average Monthly Frequency Response Performance (β) for APL Udupi for the month of July 2026- reg.

महोदय/ महोदया /Sir/ Madam,

SLDC, Karnataka vide mail dated 18.08.2026 verified and submitted the FRP Data of APL, Udupi for the month of July 2026 to RPC as per Clause 4.9 of CERC Approved Procedure. Accordingly, the Average Monthly Frequency Response (β) for APL Udupi for the month of July 2026 certified in compliance to Regulation 62 Clause 5 and Regulation 65 Clause 4 of CERC (Terms & Conditions of Tariff) Regulations, 2024 and as per CERC approved procedure dated 23.10.2024 including amendment thereof is enclosed herewith and uploaded on SRPC website (<https://srpc.gov.in>) for necessary action by all concerned.

संलग्नक: यथोपरि /Encl: as above.

भवदीय /Yours faithfully,

(असित सिंह /Asit Singh)

सदस्य सचिव //Member Secretary

Copy to:

1. CEE, SLDC-TBC, KPTCL, Bengaluru.
2. AD(Projects), PCKL, Bengaluru.

Certificate of Average Monthly Frequency Response Performance of APL-UPCL based on KPTCL data

Events from 01-07-2026 to 31-07-2026

Sl. No.	Month	Average Monthly FRP ('β')	Event -1 FRP		Event-2 FRP		Event-3 FRP	
1	July, 2026	0.72	2026-07-16-11:52:00	0.16	2026-07-19-12:36:00	1	2026-07-25-19:20:00	1